

EC-Declaration of Conformity (DoC)

We, DECKMA-GmbH, Bahnhofstraße 79, D-21224 Rosengarten-Klecken

declare under our sole responsibility, that the product

Addressable Fire Detection - and Alarm - System AFMS3000

is in conformity with the following standard(s) as described as item no. MED/3.51a and MED/3.51b in the directive 2014/90/EU and the Commission Implementing Regulation (EU) 2017/306 (of 6th February 2017 - indicating design, construction and performance requirements and testing standards for marine equipment):

International Standards:

- EN 54-2(1997) including AC(1999) and A1(2006)
- EN 54-4(1997) including AC(1999), A1(2002) and A2(2006)
- IEC 60092-504(2001) including Corrigendum 1(2011)
- IEC 60533(1999)

EC Type-Examination Certificate No. : MEDB00003Z7 / Issue date 23. March 2018

Issued by (Notified Body name/number): DNV GL / Notified body no. 0098

Quality System Certificate No. / Issue date: MEDD00001GE / Issue date 28. March 2018

Issued by (Notified Body name/number): DNV GL / Notified body no. 0098

Rosengarten, 03.April 2018

DECKMA GmbH
Bahnhofstraße 79
21224 Rosengarten-Klecken
Tel. 04105-65 60-0 / Fax 04105-65 60-25
Sven Torbeck – General Manager